



Hawaii Energy Facts & Figures

May 2015



Hawaii Energy Overview

Electric Utilities

Electric Utilities: Customers & Rates

Renewable Energy:

Renewable Energy: RPS

Bioenergy

Electric Vehicles

Geothermal

Hydropower

Oahu-Maui Grid Tie

Ocean

Smart Grid

Solar

Wind

Permitting

Energy Efficiency:

Energy Efficiency Portfolio Standards

Energy Performance Contracting

State of Hawaii Agencies Lead By Example

Leadership in Energy and Environmental Design

ENERGY STAR® Buildings

Hawaii Green Business Program

GreenSun Hawaii Loan Program

End Notes/References





State of Hawaii Department of Business, Economic Development, and Tourism
Hawaii State Energy Office · energy.hawaii.gov




Hawaii Energy Overview

Hawaii is the only state that depends so heavily on petroleum for its energy needs. Whereas less than 1% of electricity in the nation is generated using oil, in 2013 Hawaii relied on oil for 70% and on coal for 14% of its electricity generation.¹




Hawaii's electricity prices are three times higher than the U.S. average.^{2,3}

Although Hawaii's electricity production and costs are still heavily reliant on oil, energy efficiency and renewable energy have been increasing⁴ in all counties.




In Hawaii, both electricity and gasoline prices follow the price of petroleum. The graph below shows the prices of Brent crude oil, gasoline, and electricity.⁵



Hawaii Energy Overview

Electricity and gasoline are just part of Hawaii's energy picture. Large quantities of jet fuel are also used (this is different from the mainland, where most petroleum is used for ground transportation). In Hawaii, roughly equal amounts of petroleum are used for electricity production, ground transportation, and commercial aviation, with the rest used for marine transport, military, and other uses.⁶



Total petroleum use 2014 (million barrels per year) ⁷	34.3	Fuel for electricity production (million gallons per year) ⁸	394
Total petroleum use 2014 (million gallons per year) ⁹	1442	Fuel for air transportation (i.e. jet fuel) (million gallons per year) ¹⁰	411
Hawaii's rank among 50 states for energy prices ¹¹	1	Fuel for ground transportation (million gallons per year) ¹²	448

Electric Utilities


Each of Hawaii's six main islands has its own electrical grid, not connected to any other island. Hawaiian Electric Company (HECO) and its subsidiaries, Maui Electric (MECO) and Hawaii Electric Light Company (HELCO), serve about 95% of the State's population.¹³ The island of Kauai is served by Kauai Island Utility Cooperative (KIUC).^{14 15}

2013	HECO	MECO			HELCO	HECO	KIUC	State Total
	Oahu	Maui	Lanai	Molokai	Hawaii	Companies Total	Kauai	
2013 Electricity Production	7,561	1,200	27	34	1,195	10,017	452	10,469
Firm capacity (MW)	1,778	262	10	12	292	2,354	431	2,785
Intermittent capacity (MW)	568	391	0	0	447	1,406	44	1,450
System Peak (MW)	1,141	195	5	6	189	Not Applicable ¹⁴	78 ¹⁵	Not Applicable ¹⁴
Residential Customer	265,772	55,301	1,469	2,649	69,719	394,910	28,371	423,281
Commercial Customers	33,756	9,356	240	562	12,918	56,832	8,343	65,175
% of KWh used by Residential	24%	34%	30%	36%	37%	27%	37%	27%
% of KWh used by Commercial	76%	66%	70%	64%	63%	73%	63%	73%

Electric Utilities

COMPETITIVE BIDDING

Hawaii’s electric utilities deliver electricity generated with their own units as well as power generated by Independent Power Producers (IPPs). If new or replacement generation is required, HECO, MECO, and HELCO are required to follow the “Competitive Bidding Framework” for new generation with capacities greater than 5 MW (Oahu) or 2.72 MW (MECO, HELCO), or receive a waiver of the competitive bidding requirements from the Hawaii Public Utilities Commission (PUC).¹⁶ Current procurement activities include:¹⁷



- HECO: A Request for Proposals (RFP) for 600-800 gigawatt-hours (or 200 MW) of as-available renewable electricity for use on Oahu is being redrafted per a July 2013 Order from the PUC. The redrafted RFP will remove references to the Lanai Wind Project and eliminate solicitations for an undersea transmission cable. Also in July 2013, the PUC opened a new docket to examine whether the cable may be in the public interest.
- MECO: On July 11, 2013, the PUC closed the competitive bidding proceedings to acquire up to 50MW of new, renewable firm dispatchable capacity generation resources on the island of Maui. The commission will consider future requests from MECO to open another proceeding to conduct a RFP for firm generation upon a demonstration of need and a plan focused on customer needs.
- HELCO: In February 2015, HELCO announced the selection of Ormat¹⁸ for a new 25 MW geothermal power plant on the Island of Hawaii. HELCO and Ormat will be commencing negotiation to contract for the sale of new power to be generated from this new geothermal power plant and submit such agreement to the PUC for review and approval.

CONVERTING MW OF CAPACITY INTO MWh OF ELECTRICITY PRODUCTION

Generators do not always produce at full capacity, due to resource limits (sun not shining, wind not blowing), maintenance requirements, or power not needed.

The “capacity factor” is the percent of time a facility is expected to operate at full capacity (or its equivalent, in terms of energy production) over a one year period. For example, if a facility has a capacity of 1 MW and a capacity factor of 100%, it will generate $(1\text{MW})^* (24 \text{ hours/day})^* (365 \text{ days/year}) = 8,760 \text{ MWh}$ per year.

CAPACITY FACTOR ASSUMPTIONS FOR RENEWABLE RESOURCES	Capacity Factors (assumed)*	MWh produced per MW capacity ¹⁹
Biomass-Direct Firing	80%	7,000
Wind (Oahu, Hawaii, Kauai)**	35%	3,100
Wind (Lanai, Molokai)	40%	3,500
Wind (Maui)	45%	3,900
Geothermal	96%	8,400
Hydro	44%	3,900
Solar (rooftop)	23%	2,000
Solar (utility)	24%	2,100
Ocean	35%	3,100

Capacity factors presented in this table are assumptions used by Booz Allen, under contract to the National Renewable Energy Laboratory, in the *Hawaii Clean Energy Initiative Scenario Analysis*, Appendix C, Slide 26. March 2012.

* Actual capacity factors may vary from the assumptions presented here. ** The Pakini Nui wind farm (on Hawaii island) generally has an annual capacity factor of over 60%.

Electric Utilities: Customers & Rates

Residential electricity use, rates, and average bills are shown below for 2013 and 2012. In general, rates were fairly stable and electricity use declined, so bills also declined.²⁰

Residential Electricity Use, Rates, and Average Bill, 2013							
	Oahu	Hawaii	Kauai	Maui	Molokai	Lanai	State
Average use (kWh/month)	523	473	464	557	329	430	514
Average cost per kWh	\$ 0.35	\$ 0.42	\$ 0.44	\$ 0.38	\$ 0.46	\$ 0.46	\$ 0.37
Average monthly bill	\$ 181	\$ 199	\$ 205	\$ 211	\$ 153	\$ 199	\$ 189

Residential Electricity Use, Rates, and Average Bill, 2012							
	Oahu	Hawaii	Kauai	Maui	Molokai	Lanai	State
Average use (kWh/month)	561	494	465	574	345	413	543
Average cost per kWh	\$ 0.35	\$ 0.42	\$ 0.45	\$ 0.39	\$ 0.46	\$ 0.47	\$ 0.37
Average monthly bill	\$ 197	\$ 210	\$ 209	\$ 222	\$ 159	\$ 192	\$ 203

FEED - IN TARIFF (FIT)

The FIT queue is now closed.²¹ Prior to this, renewable electricity suppliers with generators smaller than 5 MW would be eligible to participate in the HECO Companies' Feed in Tariff,²² supplying as-available power to the utility at constant, contracted rates over 20 years.

Feed-in Tariff (FIT) Rates, Hawaiian Electric Companies' Service Areas									
Tier	Island	Photovoltaics (PV)		Concentrating Solar Power (CSP)		On-Shore Wind		In-line Hydro	
		rate (¢/kWh)	size limit	rate (¢/kWh)	size limit	rate (¢/kWh)	size limit	rate (¢/kWh)	size limit
1	All Islands	21.8*	20 kW	26.9*	20 kW	16.1	20 kW	21.3	20 kW
		27.4**		33.1**					
2	Oahu	18.9*	500 kW	25.4*	500 kW	13.8	100 kW	18.9	100 kW
		23.8**		27.5**					
	Maui & Hawaii	18.9*	250 kW	25.4*	500 kW	13.8	100 kW	18.9	100 kW
		23.8**		27.5**					
	Lanai & Molokai	18.9*	100 kW	25.4*	100 kW	13.8	100 kW	18.9	100 kW
		23.8**		27.5**					
3	Oahu	19.7*	5 MW	31.5*	5 MW	12.0	5 MW	--	--
		23.6**		33.5**					
	Maui & Hawaii	19.7*	2.72 MW	31.5*	2.72 MW	--	--	--	--
		23.6**		33.5**					

* With tax credit of 35%. ** With tax rebate of 24.5%.

HECO and the Independent Observer submitted a joint plan to the PUC for administering the FIT queues in September 2013. The joint plan was accepted by the PUC on 12/5/14.²³ Future revisions or modifications to the FIT program will be addressed in Docket No. 2014-0192 or 2014-0183.




FIT aggregate limits: Oahu: 60 MW; Big Island: 10 MW; Maui, Lanai, Molokai (combined): 10 MW

Electric Utilities: Customers & Rates

NET ENERGY METERING²⁴

Customers who generate renewable solar, wind, hydro, or biomass energy on their own property may be eligible for “net energy metering” (NEM) to offset their own use.

- If the customer uses more electricity than is produced, the customer pays for that net amount.
- If the customer produces more electricity than used, the customer pays a minimum bill (e.g. \$17 for Oahu residential customers) or customer charge, and excess credits are carried forward to the next month, for up to 12 months.
- About 12% of Hawaiian Electric Companies residential electric utility customers had rooftop PV systems as of December 2014.²⁵
- On August 26, 2014, under PUC Docket 2001-0206, the HECO companies delivered to the PUC the Reliability Standards Working Group distributed generation interconnection plan (DGIP). The DGIP has been merged into the Distributed Energy Resource (DER²⁶) Docket (PUC Docket No. 2014-0192) along with other relevant proceedings, and is presently under review. Among other things, the DER should “include actionable strategies and implementation plans for distribution system upgrades and utilization of advanced inverter technical functionality to enable distribution circuit solar PV penetrations to be increased over time in a safe and reliable manner.”
- KIUC: New interconnections use Schedule Q²⁷ (100 kW or less) and “NEM Pilot”²⁸ (200 kW or less; 20¢/kWh for excess).




Sample Locational Value Maps for HECO, HELCO, and MECO Service Territories (<http://www.hawaiianelectric.com/portal/site/heco/menuitem.508576f78baa14340b4c0610c510b1ca/?vqnetoid=47a22314e39e8310VqVCM1000005041aacRCD&vqnextchnel=f1230488c7d00410VqVCM1000005041aacRCD&vqnextfmt=default>)

Renewable Energy


“Renewable Energy”²⁹ is energy from:

- Sun (i.e. solar)
- Wind
- Falling water (i.e. hydropower)
- Bioenergy, including biomass (e.g. crops, agricultural and animal residues, municipal and other solid waste); biofuels, and biogas
- Geothermal
- Ocean water, including ocean thermal energy conversion (OTEC) and wave energy
- Hydrogen produced from renewable energy sources



In 2014, approximately 21.3% of Hawaii’s electricity was generated from renewable sources. Renewable electricity production is primarily from bioenergy, wind, and geothermal, with solar, especially distributed photovoltaics, increasing rapidly.³⁰

Renewable resource potential, statewide, is greater than current electricity demand.³¹



Renewable Energy

Electricity must be used, transmitted, or stored at the instant it is produced. If renewable energy is not used when it's produced, it is usually curtailed (i.e., not used).


Baseload generation facilities produce energy at a constant rate. They generally do not react (ramp up or ramp down) quickly.

Dispatchable (cycling and peaking) units produce power when called upon by the utility, to fill gaps between production and load; they can ramp up and down quickly.

Independent power producer contracts may govern which units are brought on-line (dispatched) first when load is increasing, and which are taken off-line first, when load is decreasing. A new facility generally will not displace an older facility's place in the dispatch order, unless there is a technical reason for the utility to do so.

Intermittent (as-available) energy, such as from photovoltaic and wind independent power producers, may be curtailed at times of low load. The yellow line in the graph shows solar systems, on a sunny day, reducing mid-day demand for electricity from other sources.


Electric vehicle charging, if managed so that it occurs at times of low load, can use energy that otherwise may have been curtailed.



Percent of Hawaii's electricity from renewable sources (2014)	21.3%	Renewable generation required (i.e. Renewable Portfolio Standard, "RPS") by 12/31/2015 ³²	15%
Renewable generation required (RPS) by 12/31/2020	25%	Renewable generation required (RPS) by 12/31/2030	40%

"Levelized Cost of Energy" is the price per kilowatt-hour required for an energy project to break even; it does not include risk or return on investment. Costs (land, construction, labor) are different for every project.


The Transparent Cost Database³³ compiles cost information from studies and projects across the United States. The box & whisker chart below shows the data distribution using five numbers: The minimum (bottom of the whisker), lowest 25% (below green box), median, highest 25% (above blue box), and maximum point (top of the whisker). Where fewer than three data points are available, the individual data points (green diamonds) are shown. Yellow diamonds are US Department of Energy estimates.



Renewable Energy: RPS


Renewable Portfolio Standard (“RPS”) Compliance³⁴

“The Hawaiian Electric Companies’ RPS Status Report is filed annually and calculates the RPS percentage based on total sales for the previous calendar year in accordance with the RPS law. This RPS Compliance metric estimates the percent of sales that is represented by renewable energy. This metric approximates how the RPS will be calculated from 2015 forward when electrical savings from energy efficiency and solar water heating will not be counted towards achievement of RPS compliance.”




System Renewable Energy (“System RE”)³⁵

“The System Renewable Energy metric differs from the Renewable Portfolio Standard because it estimates the percent of total net generation that is represented by renewable energy rather than being based on sales. Net generation is the amount of electricity generated and transmitted to the utility grid from the source (i.e., power plant). Generation from independent power producers (“IPPs”) and utility power plants is recorded at the net generation level. Sales are lower than the net generation due to losses in transmitting the electricity from the source to the customers. Therefore, the System Renewable Energy will result in values lower than the RPS.”



Total Renewable Energy (“Total RE”)³⁶

“The Total Renewable Energy metric differs from the RPS because it is based on total energy and not sales. Similar to the RPS, the contribution from customer-sited renewable generation is included as part of the renewable energy generated and must also be added to the total net generation of the system.”



Bioenergy

“Bioenergy” includes both electricity generation and fuel production from biomass.

Biomass is plant and animal matter, including energy crops, wood, grasses, algae, vegetable oils, and agricultural and municipal wastes. Bioenergy production potential in Hawaii depends on the availability of land and feedstock; CO₂ sources (for algae); markets and values for primary products (electricity, fuels) and by-products (animal feed); and overall revenues compared to costs.

Fuel ethanol could be blended with petroleum-based fuels. Hawaii’s energy consumption estimates for major energy sources in 2012 are shown below:



Hawaii’s Energy Consumption Estimates³⁷

Coal (Thousand Short Tons)	803
Natural Gas (Billion cubic feet)	3
Petroleum (Thousand Barrels)	42,359
Hydroelectric Power (Million Kilowatt-Hours)	115
Fuel Ethanol (Thousand Barrels)	1,250

Bioenergy facilities:³⁸

- Kauai:
 - Green Energy is planning to build a facility that will produce 6.7 MW from woodchips.
 - Pacific Light & Power is planning to develop a High Solids Anaerobic Digestion project that will produce 4.5 MW from organic material.
- Oahu:
 - H-POWER³⁹ produces 10%⁴⁰ of Oahu’s electricity from more than 600,000 tons of waste.
 - Hawaii Gas’ Campbell Industrial Park Synthetic Natural Gas Facility produces 0.1 MGY and aims to increase the renewable components of its gas supply.
 - HECO’s Campbell Industrial Park Generating Station simple-cycle unit produces 110 MW from sustainable biodiesel.
 - HECO is planning to own and operate a biofuel capable power plant at Schofield Barracks that will produce 50 MW.
 - Honolulu International Airport is planning to build 4 generators for their Emergency Power Facility that will produce 10 MW from renewable fuel.
- Maui:
 - Hawaiian Commercial and Sugar’s (HC&S) 2 steam plants and 3 hydroelectric plants produces 16 MW from renewable crop sources.
 - Maui County has contracted for an Integrated Waste Conversion and Energy Project that will produce at least 1.5 MW.⁴¹
 - Maui Electric Co. is planning to develop a Mahinahina Energy Park that will produce 4.5-6 MW energy from sorghum or other energy crops.
- Hawaii Island: Hu Honua is planning to develop biomass generators that will produce 21.5MW from eucalyptus biomass.

Bioenergy

Waste materials (such as used cooking oil) and by-products from food, feed, or fiber production, although limited in quantity, are often the first bioenergy feedstocks due to their relatively low cost and the need for reduced waste management costs.

Since biodiesel fuel imports for electricity production began in 2010, the relative cost of the imported biodiesel fuel has been significantly higher than for the fossil-based fuels used for electricity generation in Hawaii.⁴² In December 2014, fuel oil averaged \$108.22/bbl, diesel fuel averaged \$122.02/bbl, and biodiesel averaged \$210.11/bbl.⁴³

Crops may also be cultivated to produce biomass materials (oils, fiber, sugar) usable for electricity or fuel production. Studies conducted in 2010 indicate that 136,000 suitable acres could be available without displacing current farming in Hawaii; with biomass production of 10 - 20 tons of fiber per acre per year, potential would be about 1.4 - 2.7 million tons of biomass per year.⁴⁴ As a reference, two million tons of biomass, if burned in conventional biomass combustion processes, would generate energy equivalent⁴⁵ to two million barrels (84 million gallons) of oil.

Algae has also been receiving attention, due to high yields per acre and potential use of CO₂. The 8.3 million tons⁴⁶ of CO₂ produced by large energy facilities (power plants and refineries) in Hawaii could theoretically support the production of over 0.56 million gallons of oil per year.

Hawaii Biofuel Projects⁴⁷

Facility	Input (feedstocks)	Output (products)	Production Capacity
Aina Koa Pono	1. Remove invasive species. 2. Plant crops.	Renewable diesel, gasoline, biochar	16-24 million gallons per year (mgy) (planned)
Big Island Biodiesel	Used cooking oil, grease trap waste, crop oils	Biodiesel, glycerin, animal feed	5 mgy (built)
Cellana	Algae	Algae oil, animal feed	2500+ gallons per year per acre by 2018 (built)
Hawaii BioEnergy, LLC Renewable Fuels Project	Eucalyptus, energy grasses, other	Renewable fuel oil, jet fuel, gasoline; feeds, fertilizers, electricity possible	Fuel oil replacement: 10-20 mgy (planned)
Hawaii Gas Renewable Natural Gas (RNG) Plant	Animal and plant fats and oils	Renewable methane, hydrogen, propane	1 mgy (built)
Kauai Algae Farm	Algae	Algae oil	TBD (built)
Pacific Biodiesel Honolulu Plant	Local feedstock and cooking oil	Biodiesel	1 mgy (built)

Biofuel, a renewable energy source that can be stored and transported in a manner similar to fossil fuels, can often be used in existing equipment and be blended with petroleum fuels. One ton of biomass replaces approximately one barrel of oil.

Hawaii's current use of petroleum-based fuels (million gallons/yr)	1,800	Algae oil yields demonstrated on Kauai ⁴⁸	2000 gal/acre
Hawaii's current cost per gallon of biofuels ⁴⁹	\$5	Hawaii's potential liquid biofuel waste production (mil gal/yr) ⁵⁰	97
Hawaii's current cost per kWh for biofuel generated ⁵¹	60¢/kWh	Hawaii's potential ethanol production from energy crops ⁵²	1202

Electric Vehicles

An electric vehicle (EV) uses electricity in place of gasoline, reducing the need for petroleum-based fuel. Since EVs can use electricity produced from renewable resources available in Hawaii (i.e. sun, wind, hydropower, ocean energy, geothermal energy), the transition from gasoline fueled vehicles to EVs supports Hawaii's energy independence goals.



Based on statewide averages, the amount of fossil fuel used to power an electric vehicle in Hawaii is 31% less than the fossil fuel required to power a similar gasoline-fueled vehicle.⁵³ This is expected to get even better as renewable energy increases in Hawaii.

Registered EVs and Public Charging Stations in Hawaii, May 2015⁵⁴

County	Electric Vehicles	Level 2 ⁵⁵ Charging Station Ports	Level 3 ⁵⁶ Charging Station Ports	Total Ports
Oahu	2,571	244	5	249
Maui	629	68	35	103
Hawaii	160	51	2	53
Kauai	118	32	1	33
Total statewide	3,479	395	43	438

Fuel Cost Comparison

Vehicle	2014 Nissan Versa	2014 Honda Civic	2014 Nissan LEAF ⁵⁹
Fuel Type	Gasoline	Gasoline	Electricity
Miles Per Gallon (MPG)	30 mpg Combined 324 miles total range	35mpg Combined 462 miles total range	114 Combined MPG 84 miles total range
Fuel Costs	\$ 4.25/gallon	\$ 4.25/gallon	Electricity: \$ 0.38/kWh
Cost to Drive 25 Miles	\$ 3.54	\$ 3.04	\$ 2.85
Fuel Cost per Year ⁶⁰	\$ 1,700	\$ 1,450	\$ 1,400

Fuel cost comparisons show approximate savings between internal combustion engine and electric vehicles. The example above shows that fuel costs are lower for the Nissan LEAF than for a comparable gasoline fueled vehicle.

Hawaii EV Dealers by County

County	Nissan LEAF	GM/Chevy Volt	Mitsubishi iMiEV	Toyota plug-in Prius	Ford Focus, C-MAX, Fusion	BMW i3	Cadillac ELR	Porsche Panamera S E-hybrid	Tesla	Kia (estimated summer 2015)
Oahu	3	3	1	3	4	1	1	1	1	3
Maui	1	1	0	1	1	0	0	0	0	1
Hawaii	1	1	0	2	0	0	0	0	0	2
Kauai	1	1	0	1	1	0	0	0	0	1
State of Hawaii	6	6	1	7	6	1	1	1	1	7

Electric Vehicles

Hawaii's electric vehicle policies and incentives include:

- Free parking is provided in state and county government lots, facilities, and at parking meters. (Act 168 of 2012, Hawaii Revised Statutes, 291-71, Note)
- Vehicles with EV license plates are exempt from High Occupancy Vehicle lane restrictions. (Act 168 of 2012, Hawaii Revised Statutes, 291-71, Note)
- Parking lots with at least one hundred public parking spaces are required to have at least one parking space, equipped with an EV charging system, reserved exclusively for EVs. (Hawaii Revised Statutes 291-71)
- Non-EVs parked in a space designated and marked as reserved for EVs shall be fined not less than \$50 nor more than \$100. (Hawaii Revised Statutes 291-72)
- Hawaiian Electric Co. offer EV Time of Use Rates designed to incentivize customers, through lower rates, to charge their EVs during off-peak times of day.
- Multi-family residential dwellings or townhomes cannot prohibit the placement or use of EV charging systems altogether. (Hawaii Revised Statutes, 196-7.5)

EV Quick Facts

The first car to arrive in Hawaii was Electric. ⁶¹	Year 1899
Amount of energy a fully charged Nissan LEAF has potential to tap	24kWh
Best temperature range to operate lithium ion batteries (most common EV batteries today).	68° - 95° Fahrenheit
Hawaii ranks second in the nation behind California in the number of EVs registered in the state registered light cars and trucks in Hawaii are Electric. ⁶²	4.2 out of every 1,000 registered light cars and trucks in Hawaii are EV
Cost for a government or commercial property owner to install a Level 2 charging station is	Approximately \$6,000-\$8,000 per station. A relatively simple project in Hawaii can range from \$4,000 to \$25,000; however, prices vary considerably. ⁶³



EV Stations Hawaii


The Hawaii State Energy Office developed a mobile app designed to help drivers locate publicly available EV charging stations statewide. *EV Stations Hawaii* helps drivers pinpoint charging stations as well as provide detailed information of the station giving them the confidence that they can recharge while on the road. The free app is available for Apple and Android smartphones and mobile devices.

<http://energy.hawaii.gov/testbeds-initiatives/ev-ready-program/ev-stations-hawaii-mobile-app>

EVs on the Move

EVs have a greater initial purchase price⁵⁸ than comparable gasoline-fueled vehicles. Most experts, including Hawaii's auto dealers, believe that widespread acceptance of EVs will grow as a full battery charge provides greater driving range and the cost of EVs more closely matches the cost of conventional internal combustion engine (ICE) vehicles.

Geothermal



Map of Geothermal Resource Areas (Source: GeothermEx, 2005)

Continued geothermal exploration will contribute to better understanding of Hawaii’s geothermal resources. Ormat is exploring on Maui, focusing on the southwest rift zone of Haleakala, with partial funding from the U.S. Department of Energy (USDOE). The University of Hawaii (UH) is also exploring rift zones on Hawaii Island using a non-invasive technique called magnetotellurics designed to detect subsurface electrical conductivity. The Hawaii Play Fairway Project, managed by UH and supported by USDOE, will compile and integrate all geothermal-relevant data across the state into a map showing the probability of encountering a resource in the subsurface. In essence, this will provide the first statewide geothermal resource assessment conducted since the late 1970s.

Geothermal resources are difficult to characterize without exploration and drilling since Hawaii’s high-temperature resources are usually more than a mile beneath the surface. However, estimates from exploration efforts in the 1970s and ‘80s indicate that there may be more than 1,000 MW of geothermal reserves⁶⁵ (recoverable heat at drillable depths) on Maui and Hawaii islands, which would be sufficient to collectively power Maui, Hawaii Island, and about one quarter of Oahu or, alternatively, about 60% of Oahu’s energy needs. Reaching that level of production would require interconnection of the islands’ grids. Geothermal electricity is cheaper than that produced from petroleum fuels in Hawaii, and also generally cheaper than other forms of renewable electricity.

Hawaii’s single geothermal power plant, Ormat’s Puna Geothermal Venture (PGV) facility located on the Island of Hawaii, produced 255 gigawatt-hours (GWh) in 2014 which was approximately 24% of the total electricity distributed on Hawaii Island in 2014⁶⁴. The PGV facility, which began operating in 1993, produces both baseload and dispatched electricity.

In August 2014, the Hawaii Electric Light Company (HELCO) filed an updated Power Supply Improvement Plan with the Hawaii Public Utilities Commission (PUC) which specifies additional geothermal generation on the west side of the island by 2025 and no additional geothermal capacity on the east side of the island. Resulting from a request for proposals issued by HELCO in November 2012; in February 2015, HELCO announced it had selected Ormat to provide HELCO with 25 megawatts (MW) of new geothermal power on Hawaii Island. The next step in this process is for HELCO and Ormat to negotiate a contract for the sale of the new power to be generated. If an agreement is reached, it will be submitted to the PUC for review and approval. All other applicable facility permits and approvals would be required. The location of the proposed new facility is not yet publically available.

Current geothermal production Capacity in Hawaii	38 MW	Contracted price for first 25 MW of electricity from PGV ⁶⁶	18.8¢ on peak 15.9¢ off peak per kilowatt-hour (kWh)
Estimated probable reserves, Maui & Hawaii	1,000 MW	Contracted price for next 5 MW	11.8¢ / kWh
Median levelized cost of geothermal energy, U.S. ⁶⁷	6¢ per kWh	Contracted price for next 8 MW	9¢ / kWh

Hydropower

Hydroelectricity was the first renewable energy technology used to generate electricity in Hawaii; plants date back to 1888.⁶⁸ Early hydroelectric facilities were located in Honolulu and Hilo, and on the island of Kauai. During the sugar era, additional hydroelectric plants were installed to help power sugar operations.

The technology is fully commercial and reliable but is limited by fluctuating water levels in Hawaii’s streams and irrigation ditches. Due to our geology, run-of-the-river and run-of-the-ditch systems, which have no dams, are used (also see pumped hydro storage in right column). Both small, home-scale plants and utility-scale facilities are in operation.

Hawaii currently has about 31 megawatts (MW) of hydroelectricity capacity statewide, or about 1% of the state’s total power capacity.⁶⁹ In 2014, hydropower accounted for approximately 3.7% of the renewable energy generated by the three Hawaiian Electric Industries utilities: HECO, MECO, and HELCO.⁷⁰

Hydro is an important part of the energy portfolios on Kauai, where it represents 8% of the electricity sold in 2013, and on the island of Hawaii, where it generated 3% of the island’s electrical sales in 2013.⁷¹ Kauai Island Utility Cooperative (KIUC) continues to investigate new hydroelectric projects which, if successful, could provide more than 20% of the island’s annual electricity requirements.⁷²



1.1-MW Waiau Hydro Power Plant on the Wailuku River, Hilo

Hawaii Hydropower Assessments

As part of the Oak Ridge National Laboratory’s National New Stream Development project, approximately 145 MW of undeveloped hydroelectric potential have been identified in Hawaii. That potential comes from 47 hydro sites identified in reconnaissance and feasibility reports. Most of the potential sites are small run-of-the-river projects.⁷³ The U.S. Army Corps of Engineers (USACOE) also conducted a Hydroelectric Power Assessment for the State of Hawaii in 2011.⁷⁴ This feasibility study identifies, evaluates, and recommends solutions to address the potential hydroelectric power needs in the State of Hawaii. USACOE studied more than 160 hydro sites and ocean energy areas across Hawaii as part of this assessment.

Pumped storage hydro is a related technology. A non-hydro source of electricity (e.g., wind, solar, conventional generation) is used to pump water from one reservoir to a second, higher reservoir. The water stored in the upper reservoir can be released as needed, running through a turbine on the way back down and generating power. KIUC is investigating the possibility of financing and owning a 25 MW pumped storage hydro facility on Kauai using the Puu Lua Reservoir,⁷⁵ which was one of the four project sites of focus in the 2011 USACOE Hydropower Assessment.

Another related technology is in-line hydro, which harvests energy within water pipelines. For instance, the Hawaii County Department of Water Supply (DWS) has three small in-line hydro power plants which each have capacities of 40 kW. These facilities capture the energy in pipes carrying water to DWS customers in West Hawaii.



Grand River Dam Authority (GRDA) Salina Pumped-Storage Project, Oklahoma



Hawaii County Dept. of Water Supply’s 45-kW in-line hydro plan in Kona


MW of hydroelectric capacity installed statewide	31 ⁷⁶	Capacity of Wailuku River hydroelectric plant, the state’s largest	12.1 ⁷⁷ MW
Year that Puueo hydro power plant, still in operation, began generating	1910 ⁷⁸	Combined power Wailuku River, Waiau, and Puueo Hydro in 2013 ⁷⁹	16.45 MW

Oahu-Maui Grid Tie


The Interisland Cable Grid-Tie Project (a.k.a., the Oahu-Maui Interisland Transmission System) is an investigation by the Hawaii Public Utilities Commission (PUC) into the viability of connecting the electricity grids of Maui and Oahu with a 200 MW High Voltage Direct Current (HVDC) cable. DBEDT is strongly in favor of the project due to the significant economic, environmental and community benefits that it will bring to Hawaii ratepayers. The Cable is a key enabler of achieving the state’s Renewable Portfolio Standards (RPS).

The type of system being proposed is a two-way “grid-tie” (not the one-way “gen-tie” transmission cable that was proposed earlier). This adds significant value to Hawaii’s public and ratepayers because it will allow Oahu and Maui to coordinate operation of their respective electric grids, and provide flexibility to add significantly more clean, renewable energy generation in the most economical and equitable manner.

Eventually, the goal is to connect Maui to Hawaii Island to create an integrated system and take advantage of the Big Island’s abundant renewable resources.



Hawaii’s islands are already connected by several telecommunications cables.



The 200 MW HVDC cable bundle is no more than 10 inches in diameter. The bundle shown in the picture is for transmission of 500 MW.

DBEDT estimates the overall savings on both islands at up to \$423 million (2020-2050) before taking into consideration the environmental benefits. Taking into account the reduction of greenhouse gases and other emissions, the net benefit would rise to \$551 million. These figures include fuels savings of approximately \$1 billion. Other significant benefits include:⁸⁰

Economic

- Lower and more uniform electricity prices for Maui and Oahu;
- Lower fuel costs and less exposure to price volatility;
- Increased capacity factors for wind generation;
- Greater utilization of lower cost generation resources;
- Reduced curtailment of intermittent renewable energy;
- Reduced environmental compliance costs; and
- Lower operating reserve requirements.

Environmental

- Lower nitrogen oxides (NOx), sulfur oxides (SOx), particulate matter (PM), and carbon dioxide (CO2) emissions;
- Higher penetration of renewable energy generation; and
- Increased flexibility in siting new renewable generation.

Public Policy

- Helps the State meet RPS requirements and the objectives of the Hawaii Clean Energy Initiative (HCEI), i.e., 40% renewable energy by 2030;
- Reduced dependence on fossil fuels; and
- A model for potentially connecting with Hawaii Island in the future.

There have been at least 22 similar projects globally, including the following noteworthy ones:

- Trans Bay Cable (California), 53 miles: 660 MW installed in 2010.
- Cross Sound Cable (New York - Connecticut), 24 miles: 330 MW installed in 2002.
- Neptune (New York-New Jersey), 50 miles: 660 MW installed in 2007.
- NorNed (Netherlands – Norway) (longest HVDC submarine cable), 360 miles: 700 MW installed in 2008.
- SAPEI (Italy) (deepest HVDC submarine cable, at 5,380 feet), 261 miles: 1000 MW installed in 2011.

Longest undersea power cable	360 miles	Deepest undersea power cable	5,380 feet
Highest capacity undersea HVDC system	2,000 MW	Estimated installed cost of Oahu to Maui grid tie ⁸¹	\$526 million
Year of installation, first HVDC undersea power cable	1954	Estimated net benefit of Oahu-Maui grid tie, (including social costs of carbon) ⁸²	\$551 million
Expected undersea transmission cable life in years	30-50	2012 legislation: regulatory structure for inter-island power cables	Act 165

Ocean

Surrounded by the Pacific Ocean, Hawaii is rich in ocean renewable energy resources. Ocean energy includes both hydrokinetic and thermal resources.

Hydrokinetic technologies tap the movement in the ocean—waves, currents and tides—to generate electricity. Ocean Thermal Energy Conversion (OTEC) makes use of the temperature differences between warm surface waters and cold, deep ocean waters.

Hawaii has superior potential for wave energy and OTEC. However, ocean current and tidal resources are not as promising with presently-envisioned technologies in Hawaii. Ocean energy research, development and demonstration projects are taking place in Hawaii and elsewhere in the world.

The Hawaii National Marine Renewable Energy Center (HINMREC) at the University of Hawaii-Manoa is one of three federally-funded centers for marine energy research and development in the nation. HINMREC worked with the Department of Defense to establish a multiple-berth wave energy test center at Kaneohe Bay, Oahu. The first new tenant, NWEI, has been selected to occupy the existing 30-meter-deep berth. An Environmental Assessment, resulting in a Finding of No Significant Impact, was completed on two new berths, at 60 m and 80 m depths, in February 2014. Construction is anticipated to begin in 2014.



OPT's PB40 PowerBuoy in Kaneohe Bay, Oahu

The first ocean wave-generated electricity ever transmitted to the grid in the USA was generated by an Ocean Power Technologies (OPT) PowerBuoy at Kaneohe Bay in 2010. In a cooperative program with the U.S. Navy, three OPT buoys were deployed from 2004 to 2011.



OTEC heat exchanger test facility at NELHA

The Natural Energy Laboratory of Hawaii Authority (NELHA) at Keahole Point, Kona, is among the world's premier OTEC research centers. Major milestones in OTEC were achieved at NELHA in the 1980s and '90s, including a 1-MW floating OTEC pilot plant, Mini-OTEC (the world's first demonstration of net power output from a closed-cycle plant) and other demonstrations in both open- and closed-cycle OTEC.

NELHA's cold seawater supply pipes are the deepest large-diameter pipelines in the world's oceans, extending to 2,000-foot depths. The laboratory's location, with access to both warm surface water and cold deep ocean water, makes it a prime site for OTEC R&D. Presently, Makai Ocean Engineering is operating a heat exchanger test facility at NELHA, testing components and materials. A 100-kW OTEC generator has been added to the test facility and is expected to be operational in 2015, after an interconnection study has been completed and permits obtained.

A one-megawatt OTEC demonstration facility at NELHA is in the planning stages and power plants up to 100 MW in capacity have been proposed for locations off Oahu.

Number of berths expected at Kaneohe wave test center	3	Projected Levelized Cost of Electricity (LCOE) for commercial ocean energy ⁸³	23¢-25¢/kWh
Energy potential of trade wind waves in Hawaiian waters ⁸⁴	10-15 kW/meter	Temperature of cold, deep seawater at NELHA ⁸⁵	6°C (43°F)
Number of operating hours achieved by OPT PowerBuoy PB40 at Kaneohe Bay ⁸⁶	>5,600 hours	Temperature range of warm surface seawater at NELHA ⁸⁷	24° – 28.5°C (75° – 83°F)


Smart Grid

What is Smart Grid?⁸⁸

The electric “grid” is a network of transmission lines, substations, transformers and more that deliver electricity from power plants to homes and businesses. It’s what electric lights and appliances are plugged into. A “smart grid” is one that has more automatic sensors, controls, energy storage, and intelligent systems to better manage the complexity of constantly fluctuating demand and production of electricity efficiently and cost-effectively. Some common “smart grid” components are:

- Smart (“Advanced”) Meters
 - Provide timely and detailed energy use information for customers
 - Allow for time of use rates
- Sensors, controls, and forecasting
 - Monitor conditions in real time
 - Allow higher penetration of renewables
- Energy Storage (batteries, capacitors, flywheels, pumped hydro, hydrogen)
 - Allow for increased renewable energy penetration
 - Stabilize the grid by conditioning power and smoothing fluctuations
- Demand Response (managing electricity use in response to available supply)
- DOE gave \$3.4 billion in grants for smart grid projects and grid upgrades in recent years⁹⁰

Smart Grid Market is Large⁸⁹



Existing Smart Grid Projects in Hawaii


Potential Market in Hawaii

- Residential and commercial building energy management systems may become even more effective when connected to a utility-wide smart grid.
- Over 500,000 housing units and condos⁹¹, and tens of thousands of commercial and government buildings statewide, can take advantage of smart grid technologies.
- Over \$57 million has been invested in Smart Grid demonstration projects in Hawaii.⁹²

Name	Description	Key Companies	Location
HECO Smart Grid and Smart Meter Initial Phase	First phase for an island wide rollout of smart grid technology and smart meters, pending approval by the Public Utilities Commission. During the initial phase, about 5,200 smart meters will be installed in homes and businesses. ⁹³	HECO, Silver Spring Networks, Blue Planet Foundation, Hawaii Energy	Moanalua Valley, parts of Pearl City, Kaimuki, Kahala, Diamond Head and Waikiki, Oahu
DOE Renewable and Distributed Systems Integration (RDSI) Maui Smart Grid Demonstration Project	Develop a distribution management system that aggregates distributed generation, energy storage, and demand response technologies with \$7 million in DOE funds and \$8 million in industry funds. ⁹⁴	HNEI, HECO/MECO, General Electric, First Wind	Maui Meadows and Wailea, Maui
JUMPSmart Maui Project	Develop advanced technologies that automate EV charging and demand response to allow more renewable energy on the grid. NEDO will invest \$37 million in the project. ⁹⁵	NEDO, Hitachi, Mizuho, Cyber-Defense, US DOE, NREL, HECO/MECO, HNEI, MEDB, Maui County & DBEDT	Kihei, Maui
KIUC Smart Grid Demonstration	Installation of advanced metering infrastructure (AMI) and other smart grid technologies for grid management and energy efficiency information. Total cost of around \$11 million for 33,000 meters in five years. ⁹⁶	KIUC, USDOE	Kauai
Honeywell Fast Demand Response	Industrial and Commercial programs available for designating non-essential facilities that can be turned off during critical energy situations with ten minutes' notice or less. ⁹⁷	HECO, Honeywell	Oahu
Hawaiian Electric/ Stem 1 MW Distributed Storage	Stem will deploy behind-the-meter energy storage in a demonstration project with HECO to support grid response services. Stem’s energy storage and data analytics predict and respond to spikes in customers’ electricity demand. Installations are expected to be completed by March 2015. ⁹⁸	Stem, Hawaiian Electric, Hawaii Energy Excelerator	Oahu TBD. HECO and Stem will enlist commercial & industrial customers with rooftop PV.

Solar

Due to Hawaii's extremely high energy prices, superior solar resource and progressive energy policies, the state has experienced unprecedented growth in solar generation. Solar energy in 2014 provided 29 percent of Hawaii's renewable energy generation.




Solar Energy as a % of Total Renewable Generation in Hawaii 2014⁹⁹

	Number of PV Systems	Capacity (MW)
HECO ¹⁰⁰	36,042	268.9
HELCO	7,745	54.7
MECO	7,387	56.9
KIUC ¹⁰¹	1,875	12.3
TOTAL	53,409	392.8

Most photovoltaic systems are installed under the utilities' net metering program. Both residential and commercial entities participate in the program. There are approximately 51,534 photovoltaic systems currently installed, providing a capacity of 381 MW.

From 2007-2014, solar capacity nearly doubled annually. However since 2013, and due to new utility interconnection requirements, total solar generation growth has materially slowed down. The graph below shows growth Hawaii's total solar generation.



Total Photovoltaic (PV) Generation¹⁰² by Year (GWh)

Hawaii's progressive energy policies supporting PV include:

- Net Energy Metering (NEM), which allows residential customers to receive full retail value for excess solar energy occasionally fed to the grid; and
- State tax incentives.

The integration of large amounts of solar generation has proven to be a challenge for the utility due to the rapid growth of the solar industry, the intermittent nature of solar power and the condition of Hawaii's islanded, centralized electric grid infrastructure. Potential solutions include advanced or "smart" inverter settings, battery storage and interconnecting the island grids. To this end, the Hawaii State Energy Office has provided input in various technical and regulatory investigative proceedings designed to clear the current backlog of PV systems awaiting interconnection by the HECO Companies as well as modernizing the electric utility system to allow for greater renewable penetration and transparency, network interoperability and distributed intelligence.¹⁰³


Existing Utility Scale Solar Projects

Project Name	Year Installed	Island	Developer	Capacity
La Ola Solar Farm	2006	Lanai	Castle & Cooke	1.1 MW
Kapolei Sustainable Energy Park	2011	Oahu	Forest City, Hoku	1.18 MW
Kapaa Solar Project	2011	Kauai	Kapaa Solar, KIUC	1.21 MW
Port Allen Solar Facility	2012	Kauai	A&B, McBryde, KIUC	6 MW
Kalaeloa Renewable Energy Park	2013	Oahu	Hanwha Solar Energy, Swinerton, Scatec, Hunt Dev	5 MW
Kalaeloa Solar Power II	2013	Oahu	SunPower, Dept. of Hawaiian Homelands	5 MW
MP2 Solar Project	2013	Kauai	REC Solar, KIUC	300 kW
Pearl Harbor Peninsula	2013	Oahu	Forest City, NAVFAC, HECO, HOKU	1.23 MW
Koloa Solar Farm	2014	Kauai	Solar City, KIUC	12 MW

Percentage of electricity generated by solar, 2014 statewide ¹⁰⁴	5.9%	Nationwide rank of cumulative installed PV capacity per capita, 2013 ¹⁰⁵	3rd
Penetration of rooftop PV, residential ¹⁰⁶	~12%	Levelized cost of PV, Hawaii utility scale ¹⁰⁷	~13-15¢ / kWh
Power density of PV array ¹⁰⁸	11-19 watts per square foot	Watts per PV module (i.e. "panel") ¹⁰⁹	60 - 445 watts/panel
Installed cost, U.S., residential ¹¹⁰	\$3.29 / W	Installed cost, U.S., utility-scale ¹¹¹	\$1.80 / W
Statewide 2014 construction expenditures attributed to solar ¹¹²	7.4%	Acres per megawatt (Hawaii, utility-scale) ¹¹³	3.3 - 7.2 acres/MW

Wind

- Wind energy is Hawaii’s second most utilized renewable energy resource, accounting for about 30.2% of the state’s total renewable energy generation in 2014.¹¹⁴
- Hawaii has one of the most robust and consistent wind regimes in the world, with capacity factors exceeding those commonly found elsewhere. In 2011, the capacity factor of the Pakini Nui wind farm on the Big Island was 65%; Kaheawa I on Maui was 47%; and the Hawi wind farm on the Big Island was 45%.¹¹⁵
- Existing projects in Hawaii are located on the islands of Oahu, Maui, and Hawaii.




Electricity Produced from Wind Energy in Hawaii, by Island and Service Area¹¹⁶

Existing Utility Scale Projects

Project Name	Year Installed	Island	Developer	Capacity (MW)	Acres	Acres per MW
Hawi Renewable Development ¹¹⁷	2006	Hawaii	Hawi Renewables	10.5	250	23.8
Kaheawa I Wind Farm ¹¹⁸	2006	Maui	First Wind	30	200	6.7
Pakini Nui Wind Farm ¹¹⁹	2007	Hawaii	Tawhiri Power	20.5	67	3.3
Kahuku Wind Farm ¹²⁰	2011	Oahu	First Wind	30	578	19.3
Kawailoa Wind Farm ¹²¹	2012	Oahu	First Wind	69	650	9.4
Kaheawa II Wind Farm ¹²²	2012	Maui	First Wind	21	143	6.8
Auwahi Wind ¹²³	2012	Maui	Sempra Generation	21	68	3.2

Challenges Facing Wind Energy Development in Hawaii

- Endangered avian and plant species can complicate the siting and development of wind projects in Hawaii’s unique environments. Proactive measures, such as the development of area-wide habitat conservation plans, could be helpful for species protection as well as easier project siting in the future.
- Given the height of wind turbines and limited sites suitable for wind development in Hawaii, visual impacts may be of concern; they should be identified early and addressed carefully, working with local communities.



Installed Wind Energy Production Capacity by Service Area¹²⁴


Current installed wind capacity in Hawaii ¹²⁵	202 MW	Average land area used per MW of wind	9.7 acres
Height of 2.3 MW wind turbine ¹²⁶	456 ft.	Levelized cost of wind energy ¹²⁷	7¢ per kWh

Permitting

Electronic permitting is another effective method of streamlining the permit review process without removing any of the environmental or community safeguards in place.¹³⁰ Some examples of state and county agencies utilizing electronic permitting include:

e-Permitting Portal (Hawaii Department of Health / DOH)

The DOH Environmental Health Administration (EHA) *e-Permitting Portal* provides access to environmental permit applications. *e-Permitting* allows for efficient and accurate electronic application compilation and submission, tracking, processing, management, and fee payment. (<https://eha-cloud.doh.hawaii.gov/epermit/>)



Online Building Permits (City and County of Honolulu/CCH)



CCH's Department of Planning and Permitting website provides for the electronic submission and processing of building permits required for residential solar heating, photovoltaic, and electric vehicle charger installations in the City and County of Honolulu. Building Permit status can also be monitored online. (http://dppweb.honolulu.gov/DPPWeb/Default.aspx?PossePresentation=OnlineBuildingPermit&PosseObjectDef=j_OnlineBP)

Electronic Plan Review and Building Permit Status (County of Kauai)

Kauai's Department of Public Works, Building Division, offers online tools to submit building permits electronically (Electronic Plan Review or "ePlan") and get information on Building Permit status, details, and other relevant information. (<http://www.kauai.gov/Government/Departments/PublicWorks/BuildingDivision/ElectronicPlanReview/tabid/392/Default.aspx>)



[UNDER DEVELOPMENT] Online Permitting (Department of Land and Natural Resources)

DBEDT and DLNR are currently developing new online permitting tools for DLNR's Engineering Division and Division of Forestry and Wildlife. These tools are scheduled for public release in late 2015.

Facts about permitting renewable energy projects in Hawaii


- Permitting costs in Hawaii can range from 1% to 20% of overall project construction costs.¹³¹
- Large energy projects in Hawaii average 15 federal, state, and county permits.
- It can take 1-5 years to permit a large renewable energy project in Hawaii.
- Hawaii's Energy Policy: Balance technical, economic, environmental, & cultural considerations.

Common solutions to renewable energy permitting issues in Hawaii

- Know the requirements and processes - retain professionals with experience in Hawaii.
- Meaningful community participation - engage public early in the project design process.
- Engage all stakeholders - identify and address all issues early in the process.
- Site projects appropriately - minimize environmental impacts, seek compatible areas.
- Be diligent - go slow in the beginning to go fast in the end.
- 1 submittal / 1 review - present agencies w/ well-planned projects, complete applications.
- Electronic permit processing - saves time, reduces back & forth, transparency, tracking.

Energy Efficiency Portfolio Standards

This graph shows Hawaii Energy Efficiency Portfolio Standard (EEPS) levels from 2008-2014. The EEPS requires that by 2030 annual energy savings amount to 30% of annual electricity sales statewide. Excluding KIUC, we are at 21.3% for the RPS (vs. 18% in 2013) and 17.3% for the EEPS (vs. 15.7% in 2013) for a total of 38.6% (vs. 33.7% in 2013). An Energy Efficiency Potential Study, initiated by the Public Utilities Commission, indicates that there is the potential of exceeding this goal by 50% by 2030.



A major contributor to EEPS is Hawaii Energy (HE), a ratepayer-funded energy conservation and efficiency program that serves all islands except Kauai, which is handled by Kauai Island Utility Cooperative. HE is administered by Leidos Engineering, LLC, under contract with the Hawaii Public Utilities Commission.



For HE's program year ending June 30, 2014, the program invested more than \$32 million to deliver approximately 1.75 billion kilowatt hours (kWh) in lifetime system level energy savings at a cost of just 1.8 cents per kWh. The energy saved is enough to power 239,237 single-family homes for a year or half of all households in the state. It is also equivalent to eliminating 2.6 million barrels of oil from being imported to Hawaii and burned to generate electricity. HE delivered over \$20.4 million in incentives driving customer energy bill savings of over \$49.5 million for the first year and more than \$517 million over the lifetime of the energy efficiency measures installed.

Energy Performance Contracting

Energy performance contracting (EPC) provides building owners with the opportunity to design, install, and maintain energy-efficient equipment without significant upfront cost. Costs are paid over time from the energy savings. DBEDT provides technical assistance on energy performance contracting to state and county agencies.

Twelve projects initiated since 1996:

- University of Hawaii at Hilo
- Hawaii Health Services Corporation
- Judiciary
- Department of Accounting and General Services Phase I
- Department of Accounting and General Services Phase II
- Department of Public Safety (4 prisons)
- Department of Transportation - Airports
- University of Hawaii Community Colleges
- Counties of Hawaii and Kauai; C&C of Honolulu

Preliminary data show:

- The projects include over 190 buildings and over 14 million square feet
- Annual cost savings for all projects is over \$40 million, representing an average of nearly 45% savings
- Hawaii is ranked 1st in the nation per capita for energy performance contracting (Energy Services Coalition)

Over 20 years, the projects will:

- Save over \$830 million in electricity costs
- Provided over \$469 million of direct (total investment) and indirect (repair/maintenance/taxes) impacts to the economy
- Claim over \$6 million in rebate incentives
- Created over 2,670 jobs due to contract investments

Energy Performance Contracting

Hawaii honored with national energy award for third consecutive year

For the third consecutive year, the State of Hawaii was nationally recognized and awarded the Energy Services Coalition's (ESC)* Race to the Top for leading the nation in per capita energy performance contracting for state and county buildings. Hawaii led the nation with \$235.74 invested per capita; national average is \$48.93 per capita. Hawaii was well ahead of second place Kentucky with EPC investment of \$172.84 per capita and third place Delaware at \$154.47 per capita.

The State Energy Office has been providing technical assistance for performance contracting to state agencies and counties since 1996. The EPC projects vary widely and include courthouses, community colleges, hospitals, prisons, and airports.

*ESC is a national nonprofit organization, composed of a network of experts from a wide range of organizations, working together at the state and local levels to increase energy efficiency and building upgrades through energy performance contracting.

State and County Energy Performance Contracting Projects

Over \$315 million in EPC contracts awarded in Hawaii since the program's inception has resulted in the creation of 2,670 jobs and an energy savings of over \$830 million over the life of the contracts.

Energy savings for these projects over 20 years (over 1.9 billion kWh) is equivalent to powering an estimated total of 254,194 households for one year.

Agency	Year(s)	Contract Amount (\$)	Estimated Savings Over Life of Contract (\$)
UH-Hilo	1996	\$6,402,695	\$14,630,066
County of Hawaii	1997-2006	\$2,215,546	\$8,157,880
County of Kauai	1998-2006	\$525,965	\$1,205,990
C&C of Honolulu	2001-2005	\$11,900,205	\$36,066,761
HHSC	2001-2005	\$22,542,969	\$55,766,365
Judiciary	2003	\$1,474,406	\$9,785,036
DAGS Phase I	2009	\$36,873,266	\$72,580,767
PSD	2010	\$25,511,264	\$57,211,112
UHCC	2011	\$32,802,838	\$37,000,000
C&C Kailua WWTP	2013	\$6,054,178	\$13,693,910
DAGS Phase II	2013	\$17,400,000	\$28,000,000
DOT	2013	\$151,366,855	\$496,238,674
	Total	\$315,070,187	\$830,336,561

\$150 Million Airports Energy Performance Contract Largest Energy Performance Contract in the Nation

Hawaii is the first in the nation per capita investment for energy performance contracting.

As of December 2013, the Hawaii Department of Transportation Airports Division reports it has:

- Executed a \$150 million agreement for energy performance contracting for 12 airports statewide
- Financed the project by selling \$167.7 million of certificates in the municipal bond market
- Received an overwhelming response from market investors offering more than \$1.1 billion in orders from local Hawaii and national investors

Using EPC, the state's 12 airports statewide will be updated with the latest in energy efficient and green technology.

The project will result in the following:


- Cut energy use by 49 percent
- Save at least \$496 million in energy costs over the next 20 years

Improvements will include:


- Replacing 74,500 light fixtures and 372 transformers
- Installing 9,100 solar photovoltaic panels
- Upgrading and replacing chilled water and air conditioning systems
- Installing smart controls
- Addressing deferred maintenance such as roof repairs to accommodate the upgrades

State of Hawaii Agencies Lead By Example

During FY14 state agencies' energy consumption increased by 2.5% from FY13 levels and the state paid 2.0 % more than FY13. When comparing FY14 figures against the 2005 baseline year, energy consumption dropped 2.5%, but due to the increasing cost for electricity, costs rose 103.4%. Consumption (kWh) by agency by year is shown in the chart to the right.



The chart to the left shows the percentage of change from the baseline year (2005) each year since the Lead By Example program began. Shown are the price of oil, the average retail price of electricity (based on EIA-826 reporting, dividing utility total revenues by total kWh sold and including fuel adjustment cost), total State of Hawaii electricity costs and the State of Hawaii electricity consumption (kWh).



- State agencies have received more than \$8.13 million in efficiency rebates since 1996 from the Hawaiian Electric Company (HECO) and its subsidiaries and from Hawaii Energy. These rebates combined have resulted in estimated cumulative dollar savings of over \$150 million and electricity savings of 892 million kilowatt-hours. Over the life of the equipment, the savings will be equivalent to approximately 177,000 households' annual electricity use. In FY14 state agencies received \$776,355 in rebates.
- Twenty-one (21) state buildings have received ENERGY STAR® awards, acknowledging that they rank in the top 25% of similar buildings nationwide. Agencies are reviewing buildings to recertify existing buildings and to identify new buildings for certification.

Power Purchase Agreements

- DOT-Airports signed a 20-year power purchase agreement in 2009 for a total of seven (7) photovoltaic systems totaling 901 kW of capacity.
- Through a second round of power purchase agreements in 2011, DOT-Airports awarded development of photovoltaic renewable energy generation systems at 15 sites. Seven (7) power purchase agreements have been signed for a total capacity of 606 kW. The remaining eight (8) are pending, but are planned for an additional 2.69 MW. In an earlier power purchase agreement, DOT-Airports installed nearly 1.4 MW of photovoltaic systems at seven airports and harbors facilities in the state. A total of nearly 5.2 MW of photovoltaics has been installed.
- In January 2014, OpTerra Energy Solutions was awarded the Energy Efficiency and Sustainability Master Plan RFP. DOE is rebranding this program "Ka Hei." Under the Ka Hei Program, OpTerra will conduct whole school audits beginning 2015 to determine energy and water efficiencies for each DOE school. Based on these audits, DOE will determine the feasibility to fund these energy and water efficiency projects, either through the Ka Hei Program or using bond funds.
- State Building Code Update: The State Building Code Council voted on a proposed draft to update the International Energy Conservation Code of 2015; Administrative Rules must be prepared once the draft is approved.

	Utility kWh	Hoku kWh	Total		Utility \$	Hoku \$	Total \$
FY2008	25,593,580	0	25,593,580	FY2008	\$7,757,716	\$0	\$7,757,716
FY2009	25,319,886	217,682	25,537,568	FY2009	\$7,859,866	\$74,722	\$7,934,588
FY2010	25,183,956	1,345,475	26,529,431	FY2010	\$6,656,506	\$466,998	\$7,123,504
FY2011	24,881,079	1,432,550	26,313,629	FY2011	\$7,631,471	\$504,653	\$8,136,123
FY2012	24,520,683	1,397,630	25,918,313	FY2012	\$8,836,160	\$508,313	\$9,344,473

Leadership in Energy and Environmental Design


Leadership in Energy and Environmental Design (LEED)

The U.S. Green Building Council (USGBC) released its annual ranking of the Top 10 States for LEED, on which the State of Hawaii placed sixth. Last year, Hawaii placed ninth. The list highlights the regions around the country that are at the forefront of the movement for sustainable building design, construction and operation. Utilizing less energy and water, LEED-certified spaces save money for families, businesses and taxpayers; reduce carbon emissions; and contribute to a healthier environment for residents, workers and the larger community. The per-capita list is based on 2010 U.S. Census data and includes commercial and institutional green building projects that were certified throughout 2014. Hawaii certified 30 projects (public and private) in 2014 representing 2,657,808 square feet of real estate, or 1.95 square feet per resident. The certified buildings included numerous private developments, as well as some state and county buildings.

- Twenty-nine (29) State of Hawaii buildings are LEED certified or pending certification since 2006. An additional 43 LEED projects are in the process toward the goal of certification.
- Hawaii remains a member of the U.S. Green Buildings Council (USGBC), the non-profit entity which administers the LEED program. DAGS is developing LEED application guidelines to be used by state agencies.
- There are over 30 LEED Accredited Professionals on staff at six state agencies; DAGS, DBEDT, DOE, DOT, HPHA and UH. Currently additional state personnel are in training for this goal. The state requires all new construction and major renovation to meet LEED Silver standards, to the extent possible. DBEDT continues to offer LEED training opportunities for state agency staff. Six years ago, there was only one LEED Accredited Professional (AP) working for the state.

ENERGY STAR® Buildings

Agencies and private sector building owners and managers can benchmark buildings to compare energy usage with other buildings in their portfolio or similar buildings nationally to identify investment priorities. If a building's performance, as reflected in its ENERGY STAR score, ranks in the top 25% of all buildings of its type, it can be certified as an ENERGY STAR building. Since 2000, 75 Hawaii buildings have received the ENERGY STAR certification. They include 27 public and 48 private buildings. During this time, DBEDT has assisted with the benchmarking and certification of 36 public and private (buildings should be certified annually). The chart below shows the rapidly increasing number of ENERGY STAR certified buildings in the state.



Hawaii Green Business Program



The state's Hawaii Green Business Program assists and recognizes businesses that strive to operate in an environmentally, culturally and socially responsible manner. As a partnership between the state's Department of Health and the Department of Business, Economic Development and Tourism; the Board of Water Supply; and the Chamber of Commerce of Hawaii, the program recognizes businesses that are committed to going green by implementing energy and resource efficiency practices. Not only does energy efficiency keep

utility costs down and create a more sustainable environment, the businesses are also collectively contributing to Hawaii's energy efficiency goal. From 2009-2013, the program has assisted and recognized over 80 business and government entities, from the hospitality, commercial office, retail, restaurant and food services sectors, resulting in the following savings:

- 12.7 million kWh of energy (equivalent to powering 1,720 homes for one year in Hawaii)
- 47.93 million gallons of water
- \$3.313 million of energy cost

For more information on the Hawaii Green Business Program, visit energy.hawaii.gov/green-business-program

GreenSun Hawaii Loan Program

DBEDT is closing down the GreenSun Hawaii Loan Loss Reserve Program. Any future loan activity will be handled by the Green Energy Market Securitization (GEMS) Program. For more information on the GEMS Program, visit gems.hawaii.gov. Following is a summary of the GreenSun Hawaii Loan Loss Reserve Program and its accomplishments during its three years of operation.

Program Objectives

- A State of Hawaii credit enhancement program that was funded by a grant from the U.S. Department of Energy
- Provided local financial institutions with access to a loan loss reserve (LLR) which could cover up to 100% of actual losses
- Enabled participating lenders to:
 - Extend loan availability to a larger pool of borrowers
 - Offer more aggressive rates and terms than may otherwise be available without this credit enhancement
- Public-private partnership with the ability to leverage \$4.25 million in federal funds into \$85 million in energy efficiency and renewable energy equipment loans statewide

Program Purpose

Supported loans for all property owners

- Eligible Residential Loan Purposes:
 - ENERGY STAR refrigerators and air conditioners
 - Solar Thermal Hot Water System
 - Solar Electric (PV) System
 - Heat Pumps
 - Insulation installed with an ENERGY STAR air conditioner
- Eligible Non-Residential Loan Purposes:
 - Lighting Retrofits & Upgrades/Air Conditioning Retrofits & Upgrades
 - Solar Thermal Systems/Solar Electric (PV) Systems
 - Energy Efficiency Windows, Cool Roofs & all other installations eligible for Hawaii Energy/KIUC Rebates
 - Loan related fees
- Required energy efficiency improvements before renewable improvements were funded



GreenSun Hawaii Loan Program

Participants

- 12 participating Lenders statewide
- 42 authorized Contractors statewide

Impacts

GreenSun Hawaii was a public-private partnership that had the ability to leverage \$4.25 million in federal funds into \$85 million in energy efficiency and renewable energy equipment loans statewide

Impacts include:

- GreenSun Hawaii covered 194 low-interest loans amounting to over \$4.7 million
- The estimated energy savings for these installations is 28.9 million kWh of electricity over the life of the installations which will save participants' in excess of \$12.8 million over the life of the installations
- Annual CO2 reduction of 2,171,627 lbs. (43.4 million lbs. over the life of the installations)

Energy savings over the life of the equipment is equivalent to powering 3,916 households

Endnotes/References and Links

- ¹ U.S. Energy Information Administration, http://www.eia.gov/electricity/data/state/annual_generation_state.xls. 2013 data will be available 11/14.
- ² DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends/
- ³ http://www.eia.gov/electricity/monthly/epm_table_grapher.cfm?t=epmt_5_06_a. Table 5.6A Average Retail Price of Electricity to Ultimate Customers by End-use Sector—located at <http://www.eia.gov/electricity/monthly/>
- ⁴ Source: 2008-2014 Annual RPS Reports to the Hawaii PUC. <http://dms.puc.hawaii.gov/dms/>. RPS Docket Number: 2007-0008. Due to the unavailability of information, the "Renewable Energy and Energy Efficiency Portfolio Standards chart excludes Kauai Island Utility Cooperative information.
- ⁵ DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends/
- ⁶ Volumes. Source: *Biofuels Study*; DBEDT; 2012. http://energy.hawaii.gov/wp-content/uploads/2011/10/BiofuelsStudy_Act203_Dec2012.pdf
- ⁷ DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends-2/
- ⁸ DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends-2/
- ⁹ 1 barrel = 42 U.S. gallons.
- ¹⁰ DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends-2/
- ¹¹ Electricity: <http://www.eia.gov/state/rankings/#/series/31> (last accessed 4/14/15); natural gas: <http://www.eia.gov/state/rankings/#/series/28> (last accessed 9/24/14)
- ¹² DBEDT's Monthly Energy Trends, http://dbedt.hawaii.gov/economic/data_reports/energy-trends-2/
- ¹³ The State of Hawaii Data Book 2013 Tables 17.07 and 17.10 & Hawaiian Electric Industries 2013 Annual Report, "Generation Statistics".
- ¹⁴ KUIK grid is separate from HECO's infrastructure.
- ¹⁵ All-time system peak as reported 7/24/14 in Electric Light & Power/POWERGRID International, "Saft to supply energy storage system for Hawaii utility." <http://www.elp.com/articles/2014/07/saft-to-supply-energy-storage-system-for-hawaii-utility.html>.
- ¹⁶ Hawaiian Electric Company, <http://www.heco.com/waiverprojects>
- ¹⁷ Hawaiian Electric Company, <http://generationbidding.heco.com>
- ¹⁸ On 2/23/13, HELCO released an RFP for up to 50 MW of geothermal capacity on the Island of Hawaii. Concluding its analysis of the parties submitting application to this RFP, HELCO selected Ormat.
- ¹⁹ The amount of electricity produced per year = facility capacity x 24 hours/day x 365 days/year x capacity factor.
- ²⁰ Residential electricity use, rates, and average bill obtained from DBEDT's 2012 and 2013 Data Book, <http://dbedt.hawaii.gov/economic/databook/db2013/> & <http://dbedt.hawaii.gov/economic/databook/db2012/>. (Table 17.10)
- ²¹ The FIT queue was closed pursuant to Docket No. 2013-0194, Order No. 32499.
- ²² HECO, <http://www.heco.com/fit/>
- ²³ The FIT queue joint plan was accepted by the PUC on December 5, 2014 under Docket No. 2013-0194, Order No. 32499.
- ²⁴ Database of State incentives for Renewable Energy, http://www.dsireusa.org/incentives/incentive.cfm?Incentive_Code=HI04R&re=0&ee=0
- ²⁵ Source: PUC Docket No: 2014-0192 filed by Hawaiian Electric Industries on 1/21/15, Page 1, first bullet point under "Summary of This Filing".
- ²⁶ The DER docket proceeding was formally initiated on March 31, 2015 in PUC Order No. 32737, and calls for the utilities and other docket interveners from government, industry and advocacy groups to develop joint recommendations to 1) revise interconnection rules to allow for new distributed functions and capabilities such as energy storage or other grid-supportive services, 2) transition the current net energy metering (NEM) program, if necessary, and 3) create new market choices for non-exporting and "smart" exporting distributed energy systems.
- ²⁷ Kauai Island Utility Cooperative (KIUC), http://kauai.coopwebbuilder.com/sites/kauai.coopwebbuilder.com/files/schedule_q_eff_092012.pdf
- ²⁸ http://kauai.coopwebbuilder.com/files/42_schedule_nem_effective_june_3_2011.pdf
- ²⁹ Hawaii Revised Statutes, Chapter 269-91.
- ³⁰ Source: 2007-2013 Annual RPS Reports to the Hawaii PUC. <http://dms.puc.hawaii.gov/dms/>. RPS Docket Number: 2007-0008. KIUC RSP data for 2014 was unavailable at the time of this publication.
- ³¹ National Renewable Energy Laboratory, *Hawaii Clean Energy Initiative Scenario Analysis*, 2012; and DBEDT.
- ³² Chapter 269-91 *et seq.*, Hawaii Revised Statutes. http://www.capitol.hawaii.gov/hrscurrent/Vol05_Ch0261-0319/HRS0269/HRS_0269-0091.htm
- ³³ National Renewable Energy Laboratory, <http://en.openei.org/apps/TCDB/>
- ³⁴ http://www.hawaiianelectric.com/heco/_hidden_Hidden/Community/Renewable-Energy?cpsextcurrchannel=1
- ³⁵ http://www.hawaiianelectric.com/heco/_hidden_Hidden/Community/Renewable-Energy?cpsextcurrchannel=1
- ³⁶ http://www.hawaiianelectric.com/heco/_hidden_Hidden/Community/Renewable-Energy?cpsextcurrchannel=1
- ³⁷ Naphtha data from facility-level data, USEPA (<http://ghgdata.epa.gov/ghgp/main.do#/facility/>) and USEIA (<http://www.eia.gov/beta/api/qb.cfm?category=1017>)
- ³⁸ Aside from the sited source for endnotes #37 and #38, the source for the remaining section under "Bioenergy facilities" section was obtained from <https://energy.hawaii.gov/epd/public/energy-projects-map.html>.
- ³⁹ The Honolulu Program of Waste Energy Recovery (HPOWER) is the waste-to-energy facility of the City and County of Honolulu. http://www.opala.org/solid_waste/archive/How_our_City_manages_our_waste.html
- ⁴⁰ <http://hightechmaui.com/maui-county-continues-to-lead-the-way-in-renewable-energy/>
- ⁴¹ <http://hightechmaui.com/maui-county-continues-to-lead-the-way-in-renewable-energy/>
- ⁴² DBEDT, *Biofuels Report to the Legislature in Response to Act 203*, 2012. http://energy.hawaii.gov/wp-content/uploads/2011/10/BiofuelsStudy_Act203_Dec2012.pdf

43 DBEDT Research and Economic Analysis Division, *Monthly Energy Trend Highlights*, August 2014

44 Hawaii Natural Energy Institute, Bioenergy Master Plan, 2010. <http://energy.hawaii.gov/resources/hawaii-state-energy-office-publications>

45 Sugar industry rule of thumb, for combustion process without pre-drying of biomass (Hawaiian Commercial and Sugar, http://www.hcsugar.com/energy_and_the_environment.shtml).

46 EPA Facility Level Information on Greenhouse Gases Tool, <http://ghgdata.epa.gov/ghgp/main.do>

47 Hawaii Renewable Energy Projects Directory, Hawaii State Energy Office, <https://energy.hawaii.gov/epd/public/energy-projects-map.html>

48 With CO₂ from power plant. General Atomics, DARPA-funded Kauai algae facility, Congressional Briefings, Washington, D.C. (March 2012).

49 Source: Monthly Energy Trend, READ, DBEDT: The Potential for biofuels production in Hawaii, DBEDT.

50 Source: Monthly Energy Trend, READ, DBEDT: The Potential for biofuels production in Hawaii, DBEDT.

51 Source: Monthly Energy Trend, READ, DBEDT: The Potential for biofuels production in Hawaii, DBEDT.

52 Source: Monthly Energy Trend, READ, DBEDT: The Potential for biofuels production in Hawaii, DBEDT.

53 State of Hawaii, *Driving EVs Forward: A Case Study of the Market Introduction and Deployment of the EV in Hawaii*, 2012. http://energy.hawaii.gov/wp-content/uploads/2011/10/ReportMauiElectricVehicleAlliance_12_20_12.pdf

54 <http://dbedt.hawaii.gov/economic/energy-trends-2/>

55 Level 2 charging is at 240 volts. All electric vehicles are equipped for this type of charging. A “charger” can have one or more ports. The number of “ports” determines how many vehicles each charger can service at a time. One “port” can service one vehicle.

56 Level 3, also known as “fast charging,” can provide an 80% charge for some vehicles in less than 30 minutes, depending on vehicle and charger specifications. Not all vehicles can use fast charging.

58 Ranging from mid-\$30,000 to \$40,000.

59 Fuel cost comparisons show approximate savings between internal combustion engine and electric vehicles. The example shows that fuel costs are lower for the Nissan Leaf than for a comparable gasoline fueled vehicle. Nissan Leaf: 24 kWh battery; 0.34 kWh per mile.

60 Based on fuel prices, 45% highway, 55% city driving, and 12, 078 annual miles per year from Hawaii State Data Book. <http://dbedt.hawaii.gov/economic/databook/>

61 The Hawaiian gazette., October 10, 1899, Page 4, Image 4 <http://chroniclingamerica.loc.gov/lccn/sn83025121/1899-10-10/ed-1/seq-4/>

62 EIA <https://www.yahoo.com/autos/s/california-washington-lead-other-states-electric-car-ownership-133329346.html>

63 Hawaii State Energy Office, Report to the Maui Electric Vehicle Alliance Driving EVs Forward: A Case Study of the Market Introduction and Deployment of the EV in Hawaii (PDF)

64 2014 Annual RPS Reports to the Hawaii PUC. RPS Docket Number: 2007-0008: <http://dms.puc.hawaii.gov/dms/>.

65 GeothermEx, 2005; *Assessment of Energy Reserves and Costs of Geothermal Resources in Hawaii*.

66 HELCO avoided cost as of Sept. 1, 2014: <http://www.hawaiianelectric.com/vcmcontent/StaticFiles/FileScan/PDF/EnergyServices/Tarrifs/HECO/AvoidCost.pdf>

67 Levelized Cost of Energy Calculator and Transparent Cost Database, 46 values, last accessed Sept. 26, 2014. Minimum: \$0.04; Maximum: \$0.10; Median \$0.06. <http://en.openei.org/apps/TCDB/>

68 Myatt, Carl; *Hawaii, The Electric Century*; 1991

69 2013 Annual RPS Reports to the Hawaii PUC. RPS Docket Number: 2007-0008: <http://dms.puc.hawaii.gov/dms/>.

70 As of print, 2014 figures were not available for Kauai.

71 Source: 2007-2013 Annual RPS Reports to the Hawaii PUC. <http://dms.puc.hawaii.gov/dms/>. RPS Docket Number: 2007-0008

72 Kauai Island Utility Cooperative 2013 RPS Report, RPS Docket Number: 2007-0008: <http://dms.puc.hawaii.gov/dms/>.

73 <http://nhaap.ornl.gov/nsd/>

74 <http://energy.hawaii.gov/wp-content/uploads/2011/10/HydroelectricPowerAssess.pdf>

75 Kauai Island Utility Cooperative 2013 RPS Report, RPS Docket Number: 2007-0008: <http://dms.puc.hawaii.gov/dms/>.

76 Hawaii State Energy Office data.

77 Hawaii Electric Light Company, Inc.; “2012 Electricity Production & Purchased Power Summary.”

78 <http://www.hawaiianelectric.com/heco/Clean-Energy/Renewable-Energy-Basics/Hydroelectricity>, accessed May 2014.

79 Hawaii Electric Light Company, Inc.; “2012 Electricity Production & Purchased Power Summary.”

80 For the range of estimated net benefits, i.e., savings, in Net Present Value terms please see DBEDT’s *Initial Public Comments in Response to Hawaii Public Utilities Commission Order No. 31356*, Table 1, p 22; NextEra Hawaii LLC’s *Initial Public Comments Regarding the Public Interest Benefits of an Oahu-Maui Interisland Transmission System*, Table 1.2, p 8; and the HECO *IRP Action Plan* (Docket No. 2012-0036) Table 108, 109 and 110.

81 See DBEDT’s *Initial Public Comments in Response to Hawaii Public Utilities Commission Order No. 31356* in PUC Docket No. 2013-0169.

82 See DBEDT’s *Initial Public Comments in Response to Hawaii Public Utilities Commission Order No. 31356* in PUC Docket No. 2013-0169.

83 OpenEI Transparent Cost Database, last accessed Sept. 24, 2014, <http://en.openei.org/apps/TCDB/>. Based on Intergovernmental Panel on Climate Change (IPCC) Annex 3.

84 Data from HINMREC. <http://hinmrec.hnei.hawaii.edu/wp-content/uploads/2009/12/Wave-Resource-Report-October-11-2010.pdf>.

85 NELHA website, <http://nelha.org/about/facilities.html>

86 Data from Ocean Power Technologies, Inc.

87 NELHA website, <http://nelha.hawaii.gov/wp-content/uploads/2013/05/PIP-Aug-2013.pdf>.

88 SmartGrid.gov: http://www.smartgrid.gov/the_smart_grid

89 Worldwide Smart Grid Spending to Hit \$46 Billion in 2015: <http://www.treehugger.com/clean-technology/worldwide-smart-grid-spending-hit-464-billion.html>

90 Recovery Act- Smart Grid Investment Grants: <http://energy.gov/oe/technology-development/smart-grid/recovery-act-smart-grid-investment-grants>

91 Hawaii Data Book: <http://hawaii.gov/dbedt/info/economic/databook/db2011/section01.pdf>

92 Sum of stated investment in “Existing Smart Grid Projects in Hawaii”

93 <http://www.hawaiianelectric.com/heco/Clean-Energy/Smart-Grid-and-Smart-Meters>

94 University of Hawaii RDSI Demonstration Project: <http://www.smartgrid.epri.com/doc/Hawaii%20RDSI%20Final.pdf>

95 DBEDT Press Release: <http://energy.hawaii.gov/wp-content/uploads/2011/09/NR-MOU-Signing-NEDO-Hawaii.11.22.11.pdf>

96 KIUC Smart Meter FAQs: <http://website.kiuc.coop/content/smart-meter-faqs>

97 Honeywell Press Release: <http://honeywell.com/News/Pages/Honeywell-And-Hawaiian-Electric-To-Use-Demand-Response-To-Integrate-Renewables-And-Reduce-Fossil-Fuel-Dependence.aspx>

98 <http://www.hawaiianelectric.com/heco/hidden/Hidden/CorpComm/Stem-Strengthens-Grid-Response-for-Hawaiian-Electric-Company?cpsextcurrchannel=1>

99 Source: 2007-2013 Annual RPS Reports to the Hawaii PUC. <http://dms.puc.hawaii.gov/dms/>. RPS Docket Number: 2007-0008. 2014 KIUC RPS data was unavailable and not reflected in the 2014 statistics.

100 From HECO website, <http://www.heco.com/heco/hidden/Hidden/CorpComm/Rooftop-PV-enjoys-another-strong-year-in-Hawaii?cpsextcurrchannel=1>

101 Source: 2007-2013 Annual NEM, FIT Reports to the Hawaii PUC, <http://puc.hawaii.gov/reports/energy-reports/>

102 Source: 2007 -2013 Annual RPS, NEM Reports to the Hawaii PUC, <http://puc.hawaii.gov/reports/energy-reports/>. DBEDT calculation: solar generation (MWh) divided by HECO net sales (MWh).

103 On April 28, 2014, the Hawaii Public Utilities Commission issued a series of decisions and orders calling for the HECO Companies to provide power supply and distribution resource plans, including resolution of PV interconnection delays. In particular, see decisions, orders, and participant responses in PUC Docket No. 2011-0206 (the “RSWG Docket”); Docket No. 2014-0192 (“the DER docket”) and Docket No. 2014-0130 (“Rule 14H Docket”). <http://dms.puc.hawaii.gov/dms/index.jsp>.

104 Source: 2007 -2013 Annual RPS Reports to the Hawaii PUC, <http://puc.hawaii.gov/reports/energy-reports/>. 2014 KIUC RPS data was unavailable at the time of this report and was excluded from this statistic.

105 http://energy.hawaii.gov/wp-content/uploads/2011/09/NR_EnvironAmerica_7.23.13.pdf

106 Source: PUC Docket No: 2014-0192 filed by Hawaiian Electric Industries on 1/21/15.

107 Based on PPA waiver bids under 16 cents/kWh in PUC Dockets No. 2013-0156 and 2013-0381 and 16.1 cents/kWh in HECO’s Kahe Utility-Scale Photovoltaic (“PV”) Generating System, Hawaiian Electric Application, Verification, Exhibits 1-11; Oct. 22, 2013. PUC Docket No. 2013-0360.

108 Module output ranges from about 11 to 19 watts per square foot. Sanchez, Justine; “PV Module Selection.” In *Home Power* issue #163, October/November 2014.

109 California Energy Commission. List of Eligible SB1 Guidelines Compliant Photovoltaic Modules, Updated as of March 1, 2013. http://www.gosolarcalifornia.org/equipment/pv_modules.php

110 Represents median national price. “Tracking the Sun VII: An Historical Summary of the Installed Price of Photovoltaics in the United States from 1998 to 2013;” Galen Barbose, Samantha Weaver, and Naim Darghouth; Lawrence Berkeley National Laboratory; September 2014.

111 Represents median national price. Ibid.

112 Source: DBEDT, March 2014.

113 Maunalani, 0.3 MW, 1.5 acres; La Ola, 1.5 MW, 10 acres; Hoku/Forest City, 1.2 MW, 4 acres; Kapaa, 1.21 MW, 5 acres; Port Allen, 6 MW, 20 acres; Kalaeloa SunPower, 5 MW, 36 acres; Kaleloa Scatec Solar project, 5 MW, 20 acres; Kalaeloa Home Lands Solar, 5 MW, 29 acres.

114 Source: 2007 -2014 Annual RPS Reports to the Hawaii PUC, <http://puc.hawaii.gov/reports/energy-reports/>. Due to the unavailability of KIUC 2014 RPS data at the time of this report, statistic does not reflect KIUC’s data.

115 Wind capacity factors was computed by accessing EIA 860 and EIA 923 for the denominator and numerator, respectively.

116 Source: 2007 -2014 Annual RPS Reports to the Hawaii PUC, <http://puc.hawaii.gov/reports/energy-reports/>.

117 http://www.edf-re.com/about/press/construction_of_hawi_wind_farm_to_begin_in_november_2005 ;

http://www.nrel.gov/news/features/feature_detail.cfm/feature_id=1748

118 <http://www.businesswire.com/news/home/20120705005753/en/Wind-Announces-Completion-Kaheawa-Wind-II-Project>

119 Actual footprint is 26 acres. Personal communication, Steven Pace, 4/26/13. Parcel size is 67 acres. <http://www.hawaiipropertytax.com>.

120 <http://www.heco.com/portal/site/heco/menuitem.508576f78baa14340b4c0610c510b1ca>

121 http://hawaii.gov/dlnr/dofaw/hcp/Kahuku_HCP_Text.pdf

122 http://oeqc.doh.hawaii.gov/Shared%20Documents/EA_and_EIS_Online_Library/Oahu/2010s/2010-09-23-OA-EISPN-Kawailoa-Wind-Farm.pdf

123 <http://www.businesswire.com/news/home/20120705005753/en/Wind-Announces-Completion-Kaheawa-Wind-II-Project>

124 http://www.semprausgp.com/_/downloads/pdfs/Final_EIS_for_Auwahi_Wind.pdf

125 RPS reports. <http://dms.puc.hawaii.gov/dms/>. RPS Docket Number: 2007-0008

126 RPS reports and PUC fillings.

127 Siemens turbines at Kawailoa, 90 m hub height.

128 US Department of Energy program estimate, Transparent Cost Database, 110 values, last accessed March 24, 2015. Minimum: \$0.04; Median \$0.07; Maximum \$0.11. <http://en.openei.org/apps/TCDB/>

129 *Renewable Energy Permitting Barriers in Hawaii: Experience from the Field*, National Renewable Energy Laboratory (March 2013). <http://www.nrel.gov/docs/fy13osti/55630.pdf>

130 *NASEO Best Practices Review: Streamlined Renewable Energy Permitting Initiatives* (Nov. 2013). <http://www.naseo.org/data/sites/1/documents/publications/NASEO-Best-Practices-Review--Streamlined-RE-Permitting-Initiatives.pdf>

131 *Renewable Energy Permitting Barriers in Hawaii: Experience from the Field*, National Renewable Energy Laboratory (March 2013). <http://www.nrel.gov/docs/fy13osti/55630.pdf>

¹³¹ *Renewable Energy Permitting Barriers in Hawaii: Experience from the Field*, National Renewable Energy Laboratory (March 2013).
<http://www.nrel.gov/docs/fy13osti/55630.pdf>